

## VERIFICATION OF COMPLIANCE

No.: LVD GZES2003012370HS  
Applicant: GD Midea Air-conditioning Equipment Co., Ltd.  
Lingang Road, Beijiao, Shunde, Foshan, 528311, Guangdong,  
China  
Manufacturer: Same as applicant  
Product Name: Air-Conditioner  
Product Description: Split-Type Air-Conditioner  
Model No.: See page 2, 3  
Trade Mark: **Midea, MDV**  
Rating: See page 2, 3  
Protection against Electric Shock: Class I  
Degree of Protection: Outdoor unit: IP24  
(IU: Indoor unit, OU: Outdoor unit)  
Additional Information: Refrigerant is R32  
This verification replaces LVD GZES2002011340HS.

Sufficient samples of the product have been tested and found to be in conformity with

Test Standard: EN 60335-2-40: 2003 + A11 + A12 + A1 + A2 + A13  
EN 60335-1: 2012 + A11 + A13  
EN 62233: 2008

as shown in the

Test Report Number(s): GZES180701123417

This Verification of Compliance has been granted to the applicant based on the results of tests, performed by Laboratory of SGS-CSTC Standards Technical Services Co., Ltd. on sample of the above-mentioned product in accordance with the provisions of the relevant harmonized standards under the Low Voltage Directive 2014/35/EU. The CE marking as shown below can be affixed, under the responsibility of the manufacturer, after completion of an EC Declaration of Conformity and compliance with all relevant EC Directives. The affixing of the CE marking presumes in addition that the conditions in annexes III and IV of the Directive are fulfilled.

  
David Guo  
Senior Technical Manager  
SGS-CSTC



2020-04-03

Copyright of this verification is owned by SGS-CSTC Standards Technical Services Co., Ltd. and may not be reproduced other than in full and with the prior approval of the General Manager. This verification is subjected to the governance of the General Conditions of Services, printed overleaf.

Member of SGS Group (Société Générale de Surveillance)

No.:

LVD GZES2003012370HS

Other information added:

Model & Rating:

Model A:

IU: MSAFBU-09HRDN8-QRD0GW; MSAFBU-09HRDNX-QRD0GW;

OU: MOAB03-09HFN8-QRD0GW; MOAB30-09HFN8-QRD0GW

Model B:

IU: MSAFBU-12HRDN8-QRD0GW; MSAFBU-12HRDNX-QRD0GW,

OU: MOAB03-12HFN8-QRD0GW; MOAB30-12HFN8-QRD0GW

Model C:

IU: MSMABU-09HRDN8-QRD0GW; MSMABU-09HRDNX-QRD0GW,

OU: MOAB03-09HFN8-QRD0GW; MOAB30-09HFN8-QRD0GW

Model D:

IU: MSMABU-12HRDN8-QRD0GW; MSMABU-12HRDNX-QRD0GW,

OU: MOAB03-12HFN8-QRD0GW; MOAB30-12HFN8-QRD0GW

Model E:

IU: MSAFCU-18HFN8-QRD0GW; MSAFCU-18HRFNX-QRD0GW;

OU: MOB02-18HFN8-QRD0GW; MOB32-18HFN8-QRD0GW;

Model F:

IU: MSAFDU-24HFN8-QRD0GW; MSAFDU-24HRFNX-QRD0GW;

OU: MOCA02-24HFN8-QRD0GW; MOCA32-24HFN8-QRD0GW;

Model G:

IU: MSMACU-18HFN8-QRD0GW; MSMACU-18HRFNX-QRD0GW; MSMACU-18HRFNX-QRD0GW(GA);

OU: MOB02-18HFN8-QRD0GW; MOB32-18HFN8-QRD0GW;

Model H:

IU: MSMADU-24HFN8-QRD0GW; MSMADU-24HRFNX-QRD0GW; MSMADU-24HRFNX-QRD0GW(GA);

OU: MOCA02-24HFN8-QRD0GW; MOCA32-24HFN8-QRD0GW

David Guo  
Senior Technical Manager  
SGS-CSTC



2020-04-03

Copyright of this verification is owned by SGS-CSTC Standards Technical Services Co., Ltd. and may not be reproduced other than in full and with the prior approval of the General Manager. This verification is subjected to the governance of the General Conditions of Services, printed overleaf.

Member of SGS Group (Société Générale de Surveillance)

No.:

LVD GZES2003012370HS

Model I: IU: MA-09NXD0-I; OU: MA-09N8D0-O  
Model J: IU: MA2-09NXD0-I; OU: MA-09N8D0-O  
Model K: IU: MA-12NXD0-I; OU: MA-12N8D0-O  
Model L: IU: MA2-12NXD0-I; OU: MA-12N8D0-O  
Model M: IU: MA-18NXD0-I; OU: MA-18N8D0-O  
Model N: IU: MA2-18NXD0-I; OU: MA-18N8D0-O  
Model O: IU: MA-24NXD0-I; OU: MA-24N8D0-O  
Model P: IU: MA2-24NXD0-I; OU: MA-24N8D0-O  
Model Q: IU: MSAFBU-09HRDN8-QRD0GW; OU: MOX133-09HFN8-QRD0GW  
Model R: IU: MSMABU-09HRDN8-QRD0GW; OU: MOX133-09HFN8-QRD0GW  
Model S: IU: MSAFBU-12HRDNX-QRD0FGW; OU: MOX133-12HFN8-QRD0GW  
Model T: IU: MSMABU-12HRDNX-QRD0FGW(GA); OU: MOX133-12HFN8-QRD0GW  
Model E1: IU: MSAF10CU-18HRFNX-QRD0GW; OU: MOB32-18HFN8-QRD0GW  
Model F1: IU: MSAF10DU-24HRFNX-QRD0GW; OU: MOCA32-24HFN8-QRD0GW  
Model Q1: IU: MSAF10BU-09HRDN8-QRD0GW; OU: MOX133-09HFN8-QRD0GW  
Model S1: IU: MSAF10BU-12HRDN8-QRD0GW; OU: MOX133-12HFN8-QRD0GW  
Model E2: IU: MSAF21CU-18HRFNX-QRD0GW; OU: MOB32-18HFN8-QRD0GW  
Model F2: IU: MSAF21DU-24HRFNX-QRD0GW; OU: MOCA32-24HFN8-QRD0GW  
Model Q2: IU: MSAF21BU-09HRDN8-QRD0GW; OU: MOX133-09HFN8-QRD0GW  
Model S2: IU: MSAF21BU-12HRDN8-QRD0GW; OU: MOX133-12HFN8-QRD0GW  
Model R1: IU: MA2-09NXD0-XI; OU: MA-09N8D0-XO  
Model T1: IU: MA2-12NXD0-XI; OU: MA-12N8D0-XO  
Model R2: IU: MA-09NXD0-XI; OU: MA-09N8D0-XO  
Model T2: IU: MA-12NXD0-XI; OU: MA-12N8D0-XO  
220 V – 240 V; 50 Hz;  
Model A, B, C, D, I, J, K, L, Q, Q1, Q2, R, R1, R2, S, S1, S2, T, T1, T2: 2150 W; 10,0 A  
Model E, E1, E2, G, M, N: 2950 W; 13,5 A  
Model F, F1, F2, H, O, P: 3850 W; 17,5 A

David Guo  
Senior Technical Manager  
SGS-CSTC



2020-04-03

Copyright of this verification is owned by SGS-CSTC Standards Technical Services Co., Ltd. and may not be reproduced other than in full and with the prior approval of the General Manager. This verification is subjected to the governance of the General Conditions of Services, printed overleaf.

Member of SGS Group (Société Générale de Surveillance)